

Attention:
Jeff Stephens
Town of Westford
55 Main Street
Westford, MA 01886

Report Date: 7/6/2017

Date Sampled: 7/5/2017

Date Received: 7/5/2017

Date of Analysis: 7/5/2017

Summary Report

Sample Location	E.coli per 100 ml	Lab#
1 Nashoba Valley Tiki Pond	4	179066
2 Nashoba Valley Campers Beach	2	179066
3 Forge Village Beach	6	179068
4 Summer Village Main Beach	20	179069
5 American Legion at LSFP	37	179070
6 Lakeside Meadows (on Nab Lake)	ND	179071
7 North Beach (on Nab Lake) N.I.A.	ND	179072
8 Mary Lou Beach (on Nab Lake) N.I.A.	2	179072
9 Noble Cove (on Nab Lake) N.I.A.	4	179072
10 Edwards Beach	6	179068
11 Sandy Beach (on Nab Lake) N.I.A.	ND	179072
12 East Boston Camps (Girls Beach)	2	179075
13 East Boston Camps (Day Camp Beach)	ND	179075
14 East Boston Camps (Boys Beach)	2	179075

NT=Not Tested
ND=None Detected

DPH Limit = 235 cfu/100ml
Method of Analysis: EPA 1603

Massachusetts State Certified
Laboratory #MA1118

David L. Knowlton
Laboratory Director

RECEIVED

JUL 06 2017

WESTFORD
BOARD OF HEALTH