

Attention:
Jeff Stephens/Rae Dick
Town of Westford
55 Main Street
Westford, MA 01886

Report Date: 8/15/2018

Date Sampled: 8/14/2018

Date Received: 8/14/2018

Date of Analysis: 8/14/2018

Summary Report

Sample Location	E.coli per 100 ml	Lab#
1 Nashoba Valley Campers Beach	8	193172
2 Nashoba Valley Tiki Pond	26	193172
3 Forge Village Beach	64	193173
4 Summer Village Main Beach	8	193174
5 American Legion at LSFP	4	193176
6 Lakeside Meadows (on Nab Lake)	4	193177
7 North Beach (on Nab Lake) N.I.A.	12	193179
8 Mary Lou Beach (on Nab Lake) N.I.A.	10	193179
9 Edwards Beach	26	193173
10 Sandy Beach (on Nab Lake) N.I.A.	4	193179
11 Noble Cove (on Nab Lake) N.I.A.	6	193179
12 East Boston Camps (Boys Beach)	2	193180
13 East Boston Camps (Girls Beach)	8	193180
14 East Boston Camps (Day Camp Beach)	2	193180

RECEIVED

AUG 15 2018

WESTFORD BOARD OF HEALTH

NT=Not Tested
ND=None Detected

DPH Limit = 235 cfu/100ml
Method of Analysis: EPA 1603

Massachusetts State Certified
Laboratory # = M-MA1118


David L. Knowlton
Laboratory Director