

**Westford Water Department
PWS ID #3330000**

Our Public Water System has no Lead, Galvanized Requiring Replacement (GRR) or Unknown Service Lines

On 11/21/2024, MassDEP approved Westford Water Department's request for approval to release a statement that our system has no service lines of Lead, Galvanized Requiring Replacement (GRR) or unknown materials. This statement is based on the results of a service line inventory that was developed using the following verification method(s):

- Field Inspection by PWS
- Records Review
- Statistical Analysis
- Customer Self-Identification
- Sequential Monitoring
- Other(s) MassDEP-Approved Method(s):

Disclaimer: This statement is based on the initial service line inventory for our system as required by the Environmental Protection Agency (EPA) under the Lead and Copper Rule Revisions. This statement does not take into consideration the presence of unknown or lead service line connectors. A gooseneck/pigtail/connector is defined as a piece of pipe typically not exceeding two feet in length that connects the water main to the service line or the service line to the water meter of a building.

For information on all service lines in the Westford Water Department, contact the Westford Water Department at water@westfordma.gov or Douglas Yargeau (Environmental Compliance Manager) at dyargeau@westfordma.gov